

OFFICE USE ONLY
 Log No. 63786
 Permit No. _____
 Basin. ORB

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21668

Consultant: _____
 1. OWNER EBASCO INFRASTRUCTURE ADDRESS AT WELL LOCATION SIERRA PACIFIC POWER CO.
 MAILING ADDRESS 2525 Natomas Park Dr. Suite 250 Tracy Clark Power Station
Sacramento, Ca. 95833-2900 I-80 East, Sparks, Nevada
 2. LOCATION SW 1/4 SW 1/4 Sec. 28 T 20N N/S R. 22E E Storey County
 PERMIT NO. M/O 381-A MW 8 04-091-11 W of Cooling Pond
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface is tan GRAVELLY SAND.		0	2	2
Dry, mod., loose, gravelly silty sand.		2	6	4
Moister, cuttings hold shape when squeezed		6	9	3
More gravels and less fines. Grading to coarser sand w/gravels, gravels up to .5in. in dia.		9	15	6
Cuttings are damp		15	20	5
Cuttings are very wet, grading to gravel.				
Cuttings are SILTY SANDY GRAVELS		20	24	4

8. WELL CONSTRUCTION
 Depth Drilled 24.2 Feet Depth Cased 19.9 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 1/2 Inches To 24.2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		sch	40	0

Bottom cap, Locking cap, Flush cover
 Stainless Steel Centralizers @ 9' & 19'

Perforations:
 Type perforation Factory sawed slot
 Size perforation 0.02
 From 9.9 feet to 19.9 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 6' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 6' - 8'
 Gravel Packed: Yes No #3 Lone Star Sand
 From 8' feet to 24.2' feet

9. WATER LEVEL
 Static water level 12.9 feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

Date started 3-22-93, 19____
 Date completed 3-22-93, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No test			
Well information received via FAX 6-9-96			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed Wayne Drilling, Inc.
By driller performing actual drilling on site or contractor
 Date June 12, 1996