

OFFICE USE ONLY  
 Log No. 63824  
 Permit No. 072B  
 Basin

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13373

1. OWNER ERG, Inc. ADDRESS AT WELL LOCATION Valley Auto Center  
9205 Lemmon Valley Drive, Reno, Nevada  
 MAILING ADDRESS 9205 Lemmon Valley Drive  
P. O. Box 11525, Reno, Nevada 89510  
 2. LOCATION SW 1/4 SW 1/4 Sec. 34 T 21 N 8 R 19 E Washoe County  
 PERMIT NO. M/10 445 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. MU-2 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>BROWN SILTY SAND</u> <u>With Gravel</u>		<u>0.0</u>	<u>8.0</u>	<u>8.0</u>
<u>BROWN SILT</u>		<u>8.0</u>	<u>13.0</u>	<u>5.0</u>
<u>BROWN SAND</u>	<u>Yes</u>	<u>13.00</u>	<u>35.0</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 35.0 Feet Depth Cased 35.0 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8.0 Inches To 0.0 Feet 35.0 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.0</u>	<u>0.5</u>	<u>Schedule 40</u>	<u>0.0</u>	<u>35.0</u>

Perforations:  
 Type perforation Slotted  
 Size perforation 0.02 Inches  
 From 10.0 feet to 35.0 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 6.0  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 8.0 feet to 35.0 feet

9. WATER LEVEL  
 Static water level 24.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started September 5, 1991  
 Date completed September 5, 1991

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Mark E. DeBusk Contractor  
 Address 520 Edison Way Contractor  
Reno, Nevada 89502  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1768  
 Signed [Signature]  
 By Driller performing actual drilling on site or contractor  
 Date 10/1/91