WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 03867
Permit No.
Basin 049

NOTICE OF INTENT NO. 28[illegible]5

1. OWNER Wayne Wiese Lech McKenney
MAILING ADDRESS 337-8 Osino
Elko NV 89801

ADDRESS AT WELL LOCATION Lot 6 Block 12

2. LOCATION SW ¼ NW ¼ Sec. 3 T 35 N/S R 56 E Elko County
PERMIT NO. (Issued by Water Resources) 35-012-06-1 (Parcel No.) Osino Mur #3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	18	18
Gravel		18	23	5
Clay		23	48	25
Gravel		48	56	8
Clay		56	78	22
Gravel		78	86	8
Clay		86	172	86
Cemented Gravel		172	189	17
Clay		189	196	7
Gravel	X	196	230	34

RECEIVED 96 OCT 21 PM 1:18 STATE ENGINEER'S OFFICE

Date started 9-13, 1996
Date completed 9-15, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	25		3

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	230 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	+2	230

Perforations:
Type perforation Slots
Size perforation 3/16 x 3/8
From 210 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 52 feet to 230 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Co (Contractor)
Address P.O. Box 525 (Contractor)
Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 31704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-12-96

(Rev. 3-93)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627