

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 63878  
 Permit No. 589 103  
 Basin 89701

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28044

1. OWNER John & Dolores Bowers ADDRESS AT WELL LOCATION 320 Hwy 341 Carson City NV. 89701  
 MAILING ADDRESS 320 Hwy 341 Carson City 89701  
 2. LOCATION SW 1/4 SW 1/4 Sec. 16 T. 16 S. R. 21 E. 2-Yon County  
 PERMIT NO. 16-121-18 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Coarse Gravels		0	18	18
small Boulders				
Coarse Sands		18	48	30
Sands and Small clays Zones		48	93	45
Coarse Sands		93	162	69
Larger Gravels	XX	162	200	38
DB Sands				
Carrying Water				

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 200 Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:  
 Type perforation Mill slot  
 Size perforation 3 x 3/32  
 From 160 feet to 200 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 55  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 55 feet to 200 feet

9. WATER LEVEL  
 Static water level: 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25+ P.S.I.  
 Water temperature Cold °F Quality Good

Date started 7-26, 1996  
 Date completed 7-30, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>	<u>45</u>	<u>3 HRS.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A/H Pump Company Contractor  
 Address 5551 Hwy 50 E #3 Carson City NV. 89701 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board: 31839  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller: 1905  
 Signed Michael J. Black  
 By driller performing actual drilling on site or contractor  
 Date 7-30-96