WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63879
Permit No.
Basin 103

NOTICE OF INTENT NO. 31879

1. OWNER Dean Duncan
MAILING ADDRESS 20625 Cooke Drive
Reno, Nevada 89511

ADDRESS AT WELL LOCATION 250 Sutro
Dayton, Nevada

2. LOCATION NE ¼ NE ¼ Sec. 8 T. 16N N/S R. 22 East Lyon County
PERMIT NO. Issued by Water Resources | 16-352-05 Parcel No. | Arrowhead Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	4	
Fine Brown Sand		4	12	
Brown D.G. Sands w/ Gray Fine Sand		12	45	
Multi Colored Gravels w/ Fine Gray Sand		45	120	
Multi Colored Course Gravels w/ Fine Gray Sand	X	120	170	
T.D. 170				

Date started January 26, 1996
Date completed January 30, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 hours

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10-5/8	0	170

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	+1-1/2	170

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 X 3
From 165 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 170 feet to 50 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, INc. (Contractor)
Address 1800 1/2 Frazer Ave. (Contractor)
Sparks, Nevada 89431
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date February 1, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627