

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28055

1. OWNER Julius Burkawski (Dayton Utilities) ADDRESS AT WELL LOCATION N/A  
 MAILING ADDRESS Well #2

2. LOCATION NE 1/4 SE 1/4 Sec. 24 T. 16 N. R. 21 E. Lyon County  
 PERMIT NO. W-469 N/A/W-469 Parcel No. Behind Dayton High School Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other Test

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	4	4
Cobbles and 3/4" Gravels		4	150	146
Brown Clay		150	160	10
Large Gravels w/ Fractures	a	160	195	35
Soft Volcanic Sand		195	215	20
Brown Sandy Clay w/ Obsidian Gravels		215	230	15
Hard Broken Fracture		230	235	5
Inbedded Gravels w/ small clay seams		235	250	15
Hard Fracture Gravels	xx	250	283	33
Hard Volcanic Sands		283	300	17
Soft Sandy Zone		300	318	18
Hard Fracture Gravel	xxx	318	355	37
Volcanic Sands		355	410	55
Hard Fractured Volcanic Gravels and Sands		410	503	93

8. WELL CONSTRUCTION  
 Depth Drilled 503 Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)  
 From 8 3/4 Inches To 0 Feet 503 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>N/A</u>				

Perforations:  
 Type perforation N/A  
 Size perforation N/A feet to N/A feet  
 From N/A feet to N/A feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal N/A  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From N/A feet to N/A feet

9. WATER LEVEL  
 Static water level N/A feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A. H. Pump Company Contractor  
 Address 5551 Hwy 50 E #3 Contractor  
Carson City NV 89701

Nevada contractor's license number issued by the State Contractor's Board 80839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1985

Signed Richard J. Beck  
 By driller performing actual drilling on site or contractor  
 Date 8-26-96

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

DATE STARTED 8-21 1996  
 DATE COMPLETED 8-24 1996

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>Plugged by 116451</u>			

RECEIVED  
 96 SEP 23 11:10 AM  
 STATE ENGINEER

