

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29048

1. OWNER Pat McKillip ADDRESS AT WELL LOCATION 207 GoldCreek DR. Dayton NV.
 MAILING ADDRESS 207 GoldCreek DR. Dayton NV.

2. LOCATION NE 1/4 NE 1/4 Sec 1 T. 16 S R. 22 E Lyon County
 PERMIT NO. 19-542-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	7	7
Course Red Gravels Boulders		7	18	11
Brown Clay zone small sands		18	94	76
Hard Volcanic Gravels		94	114	20
Brown Clay		114	138	24
Course Volcanic Sands and Gravel		138	199	61
Fractures of Volcanic Sand and Gravels	xxx	199	240	41

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 240 Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>18.03</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation M. 11 slot
 Size perforation 3 x 3/32
 From 200 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. 30+ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H Pump Company Contractor
 Address 5551 Hwy 50 E #3 Contractor
Carson City NV. 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1905
 Signed Richard Black
 By driller performing actual drilling on site or contractor
 Date _____

Date started 8-15 1996
 Date completed 8-17 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30+</u>	<u>25</u>	<u>3 HRS</u>

RECEIVED
 50 AUG 19 AM 9:13
 STATE ENGINEERS OFFICE