

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31884

1. OWNER Kevin Piper ADDRESS AT WELL LOCATION 300 Imperial Road  
MAILING ADDRESS 299 Swanton Road Dayton, Nevada 89403  
Davenport, CA 95017  
2. LOCATION SW 1/4 SE 1/4 Sec 4 T. 16N N/S R. 22 East Lyon County  
PERMIT NO. 19-135-07 Dayton Velley Ranches  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown D.G. w/Fine Brown Sand		0	11	
Multi Colored Gravels w/Fine Gray Sand		11	56	
Multi Colored Course Broken Gravels w/ Gray Fine Sand		56	69	
Multi Colored Gravels w/Fine Gray Sand		69	109	
Brown Sticky Clay		109	114	
Multi Colored Gravels w/Fine Gray Sand		114	115	
Brown Sticky Clay		115	120	
Multi Colored Course Gravels w/Fine Gray Sand	X	120	220	
T.D. 220				

8. WELL CONSTRUCTION  
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)  
From 10-5/8 Inches To 0 Feet 220 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	+1	220

Perforations:  
Type perforation Factory-Sawed  
Size perforation 3/32 X 3  
From 218 feet to 198 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 53'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 220 feet to 53 feet

Date started January 30, 1996  
Date completed February 1, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		2 hours

9. WATER LEVEL  
Static water level 65 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name A.S.A.P. Pump & Well Service, Inc. Contractor  
Address 1800 1/2 Frazer Ave Contractor  
Sparks, Nevada 89431  
Nevada contractor's license number issued by the State Contractor's Board 35387-A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date February 5, 1996