

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 03887  
 Permit No. T  
 Basin 1  
 NOTICE OF INTENT NO. 34684

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **AKINS CONSTRUCTION** ADDRESS AT WELL LOCATION **466 SUNRISE TERRACE**  
 MAILING ADDRESS **2160 RICE ROAD**  
**FALLON, NV 89406**

2. LOCATION **SE 1/4 SE 1/4 Sec. 19 T 19N N/S R 29E E CHURCHILL** County  
 PERMIT NO. 008-312-34 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	18	18
BROWN CLAY		18	24	6
BROWN SAND	X	24	35	11
GREY SAND		35	60	25
BLACK SILT		60	71	11
GREY SAND		71	81	10
BROWN CLAY		81	83	2
BROWN SAND	X	83	93	10

8. WELL CONSTRUCTION  
 Depth Drilled **93** Feet Depth Cased **93** Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
**10 3/4** Inches **0** Feet **50** Feet  
**6 1/8** Inches **50** Feet **93** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	93

Perforations:  
 Type perforation **MACHINE SLOT**  
 Size perforation **.080**

From **86** feet to **91** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level **8.1** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **COOL** °F Quality **UNTESTED**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Welsco Drilling Corp.** Contractor  
 Address **305 E. WILLIAMS AVE. P. O. BOX 888** Contractor  
**FALLON, NV 89407**

Nevada contractor's license number issued by the State Contractor's Board **11752**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1996**

Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **12-11-96**

Date started **11/22/96** 19  
 Date completed **11/22/96** 19

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>30</b>		<b>1 hr.</b>