WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63892
Permit No.
Basin 089

NOTICE OF INTENT NO. 29031

1. OWNER Troy Williams
MAILING ADDRESS 1180 Brenda Way
Carson City, NV 89704

ADDRESS AT WELL LOCATION
1180 Brenda Way

2. LOCATION NW 1/4 NW 1/4 Sec. 30 T 17N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 050-252-07 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We tagged bottom at 320' and				
drilled to 420'.				
Hard grey sandstone	x	320	375	100
Green & brown stain quartz	x	375	380	5
Grey sandstone		380	382	2
See next line	x	382	420	38
Green & brown stain quartz/fractured				

Date started 6/12/96, 19__
Date completed 6/13/96, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	320	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8" Inches		320 Feet	420 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	10.79	.188	315	420

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 380 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level ~~125~~ 94 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce Mackay
By driller performing actual drilling on-site or contractor
Date 6-17-96