

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26393

1. OWNER ROC O. COLE ADDRESS AT WELL LOCATION END OF MARIE ROAD SPANISH SPRINGS, NV.  
 MAILING ADDRESS 185 WELLINGTON RENO, NV 89506  
 2. LOCATION SE 1/4 SW 1/4 Sec. 4 T. 20N N/S R. 20E E WASHBE County  
 PERMIT NO. 536A Parcel No. 83-440-25 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DSG, COBBLES, FILL</u>		<u>0</u>	<u>42</u>	<u>42</u>
<u>DSG, MED TO HARD</u>		<u>42</u>	<u>180</u>	<u>138</u>
<u>GRANITE HARD</u>		<u>180</u>	<u>315</u>	<u>135</u>
<u>GREY TO GREEN</u>	<input checked="" type="checkbox"/>			
<u>TRIPANITE</u>	<input checked="" type="checkbox"/>	<u>315</u>	<u>360</u>	<u>45</u>

8. WELL CONSTRUCTION  
 Depth Drilled 360 Feet Depth Cased 360 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 0 Feet 207 Feet  
 To 8 7/8 Inches 207 Feet 360 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>.188</u>	<u>12'</u>	<u>360</u>

Perforations:  
 Type perforation MECH. PERF.  
 Size perforation 3/32 x 1 1/2  
 From 300' feet to 360 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 360 feet

9. WATER LEVEL  
 Static water level 270 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality GOOD

Date started 5/11 1995  
 Date completed 5/18 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>PAUL</u>	<u>75</u>		<u>5 HRS.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WM BLAINE WELLS DRILLING & PUMP CO. Contractor  
 Address 2537 LARY CR. CARSON CITY, NV 89406 Contractor  
 Nevada contractor's license number 010950 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1974  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5/19/95