

OFFICE USE ONLY  
 Log No. 63897  
 Permit No. 1  
 Basin 081

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32548

1. OWNER TONY LACORTE ADDRESS AT WELL LOCATION 6455 Tomas More Cir. Sun Valley  
 MAILING ADDRESS 2070 Centennial Way, Apt. B Sparks, Nevada 89433  
Reno, Nevada 89512  
 2. LOCATION NW 1/4 SE 1/4 Sec 8 T 20 N N/S R 20 E E Washoe County  
 PERMIT NO. 083-460-25 Sun Valley Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	2	2
D.G.		2	31	29
Gray Granite		31	44	13
D.G.		44	45	1
Gray Granite		45	69	24
Weathered green granite		69	110	41
Gray granite		110	199	89
Soft zone (No Water)		199	210	11
Gray granite		210	344	134
Fracture (No Water)		344	345	1
Gray Granite		345	389	44
Fracture Granite	X	389	416	27
Gray Granite		416	425	9

8. WELL CONSTRUCTION  
 Depth Drilled 425 Feet Depth Cased 425 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 425 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	425

Perforations:  
 Type perforation Factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 380 feet to 420 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 425 feet

9. WATER LEVEL  
 Static water level 371 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
 Water temperature cold °F Quality clear

Date started 4-1-96, 19\_\_\_\_\_  
 Date completed 4-3-96, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed Wayne L. Hedman By driller performing actual drilling on site or contractor  
 Date April 4, 1996