WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 63941
Permit No.
Basin 163

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5540

1. OWNER ERNEST L BROWNING
MAILING ADDRESS Box 380 HCR 31
JEAN, NV. 89019

ADDRESS AT WELL LOCATION MARBLE ST
NEAR SICKIE

2. LOCATION SW ¼ NW ¼ Sec. 26 T. 2A N/S R. 56 E. CLARK County

PERMIT NO. (Issued by Water Resources) 100-580-250-044 (Parcel No.) N/A (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SANDY LOAM | | 0 | 2 | 2 |
| CALICHE | | 2 | 28 | 26 |
| WHITE CLAY | | 26 | 55 | 29 |
| BROWN CLAY | | 55 | 60 | 5 |
| CALICHE | WTR | 60 | 62 | 2 |
| LT BROWN CLAY | | 62 | 81 | 19 |
| WHITE CLAY | | 81 | 88 | 7 |
| LT BROWN CLAY | | 88 | 90 | 2 |
| GREEN CLAY | | 90 | 104 | 14 |
| HARD GREY CLAY | | 104 | 115 | 11 |
| CALICHE | WTR | 115 | 118 | 3 |
| HARD GREY CLAY | | 118 | 120 | 2 |

RECEIVED
SEP 12 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started AUG 10, 1989
Date completed AUG 16, 1989

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 30 Draw down 2 feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 120 feet
inches
inches
Casing record STEEL
Weight per foot 12.5 Thickness .156

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 120 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation FLAME CUT
Size perforation 3/8X4"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 66 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBB, INC. (Contractor)
Address 1701 W. Chstn, Las Vegas Nv. 89102 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020301
Nevada contractor's driller's number issued by the Division of Water Resources 1352
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352
Signed Robert Spurlock
By driller performing actual drilling on site or contractor
Date Aug 23-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627