WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

In Book

OFFICE USE ONLY
Log No. 63943
Permit No.
Basin 163

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5555

1. OWNER BRYANT CHAPMAN
MAILING ADDRESS 4324 N DECATURE
LAS VEGAS 89130 NV.

ADDRESS AT WELL LOCATION S. of MARBLE AVE.
NEAR SICKIE ST.

2. LOCATION NE ¼ SW ¼ Sec. 26 T. 24 N/S R. 56 E. CLARK County

PERMIT NO. ..... Issued by Water Resources | 580-250-051 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	1	1
CALICHE		1	24	23
BRN CLAY		24	32	8
WHT CLAY		32	40	8
BRN SANDY CLAY		40	68	27
CALICHE	WTR	68	71	3
LT BRN CLAY		71	94	23
CALICHE	WTR	94	98	4
WHT CLAY		98	132	34
CALICHE	WTR	132	138	6
BRN CLAY		138	140	2

RECEIVED
FEB 13 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Jan 14, 1991
Date completed Jan 20, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 2 feet 2 hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 140 feet
..... inches
..... inches
Casing record STEEL
Weight per foot 18.7 Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation FLAME CUT
Size perforation 3/8 X 4 4 ROWS @ 16"
From 100 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 63 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 67 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBB, Inc
Contractor
Address 1701 W Chstn, Las Vegas Nv 89102
Contractor
Nevada contractor's license number issued by the State Contractor's Board 020301
Nevada contractor's driller's number issued by the Division of Water Resources 1352
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352
Signed Robert Sourlock
By driller performing actual drilling on site or contractor
Date Feb 1, 91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627