

OFFICE USE ONLY
 Log No. 63954
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31195

1. OWNER GARY Gaudin 640 ADDRESS AT WELL LOCATION 790 Wetland View
 MAILING ADDRESS HARRIGAN RD
 2. LOCATION NE 1/4 Sw 1/4 Sec. 29 T. 19 N/S R. 28 E Churchill County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand		0	20	20
Brown clay		20	23	3
Brown sand	X	23	40	17
Grey sands		40	68	28
Grey clay		68	75	7
Brown sand / Gravel	X	75	94	19

8. WELL CONSTRUCTION
 Depth Drilled 95 Feet Depth Cased 95 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 3/4 Inches 0 Feet 50 Feet
6 1/8 Inches 50 Feet 95 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>1/8</u>	<u>71</u>	<u>95</u>

Perforations:
 Type perforation machine cut
 Size perforation .08
 From 85 feet to 95 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 9' 6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality OK

Date started 3-15 19 96
 Date completed 3-15 19 96

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Weisco Corp Contractor
 Address 335 N Broadway Contractor
FAilon
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1986
 Signed Jesus Marin
 By driller performing actual drilling on site or contractor
 Date 4-1-96