WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36969
Permit No.
Basin 212

NOTICE OF INTENT NO. 9635

1. OWNER R.C White TRANSportation Ctr.
MAILING ADDRESS Clark County School Dist. 4499 S. Arville St. Las Vegas NV
ADDRESS AT WELL LOCATION 4499 S. ARVILLE LAS VEGAS, NV

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 21 N/S R. 61 E/W CLARK County
PERMIT NO. MO-2147 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG MW-4

Material	Water Strata	From	To	Thickness
Asphaltic Concrete		0	.25	.25
Type II Agg. Base		.25	.9	.65
Silty Sand		.9	4.5	3.6
Sandy Clay		4.5	7	2.5
Clayey sand		7	12	5
Gravelly sand		12	14.5	2.5
Clayey SAND		14.5	17.5	3.0
Caliche		17.5	23.0	5.5
Clayey sand	▼	23.0	30.5	7.5
Sandy clay		30.5	36.0	5.5
Clayey gravel		36	40	4
total depth	40 ft.			

RECEIVED
MAY 04 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4/29, 1992
Date completed 4/29, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	40 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4-INCH	2 lbs/ft.	SCH 40 PVC	0	40

Perforations:
Type perforation FACTORY Shotted
Size perforation 0.020 INCH
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-8'/6'-8' Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 40 feet

9. WATER LEVEL
Static water level 25.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas, NEVADA
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources/ the on-site driller
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627