WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

In Book

OFFICE USE ONLY
Log No. 63975
Permit No.
Basin 163

NOTICE OF INTENT NO. 10334

1. OWNER WALTER + NATALIE MARTIN
MAILING ADDRESS

ADDRESS AT WELL LOCATION KOLO + ONYX AV.
SANDY VALLEY

2. LOCATION SW ¼ NW ¼ Sec. 31 T. 24 N/S R. 57 E CLARK County
PERMIT NO. (Issued by Water Resources) | Parcel No. 580-790-013 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	8	8
CLAY LOAM		8	35	27
CLAY		35	48	13
CALICHIE	TR.	48	53	5
CLAY		53	63	10
CALICHIE	WB	63	69	6
CLAY		69	82	13
CALICHIE	WB	82	86	4
CLAY		86	102	16
CALICHIE	WB	102	109	7
CLAY		109	128	19
CALICHIE	WB	128	131	3
CLAY		131	134	3
CALICHIE	WB	134	138	4
CLAY		138	140	2

Date started 10-31, 1992
Date completed 11-4, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
NOV 10 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAWCUT
Size perforation ¼ INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Dennis Brown (By driller performing actual drilling on site or contractor)
Date 11-4-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627