WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

in Book

OFFICE USE ONLY
Log No. 63983
Permit No.
Basin 163

1. OWNER Reinaldo Del Cristo ADDRESS 3234 Holmes Las Vegas, NV. 89109

2. LOCATION NE ¼ SW ¼ Sec. 36 T. 24 N/S R. 56 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sandy clay		0	15	15
Gray clay		15	62	47
Red clay	W	62	78	16
Brown clay & gravel	W	78	110	32
Sand & Gravel with some clay	W	110	120	10

RECEIVED
JAN 10 1984
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 11-18, 19 83
Date completed 12-3, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 50 Draw down 0 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 120 feet
Casing record 120' of 8"
Weight per foot Thickness .156

Diameter	From	To
8" inches	+1 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50' feet to 120' feet

Perforations:
Type perforation TORCH
Size perforation 1/4" X 12"
From 80 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 47 Feet below land surface
Flow — G.P.M. —
Water temperature cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Denzil L. Babcock
Address 5804 Jerry Dr
Nevada contractor's license number 21173
Nevada driller's license number 1256
Signed Denzil L. Babcock
Date 12-28-83
NOTICE OF INTENT # 0253

USE ADDITIONAL SHEETS IF NECESSARY

O-627