WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 63989
Permit No.
Basin 163

1. OWNER JAMES A. GERWIG ADDRESS 355 E CATALINA, RD LV NV 89119
10 ACRES SANDY VALLEY

2. LOCATION NW¼ NE ¼ NW ¼ Sec. 36 T. 24S N/S R. 56 E. CLARK County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
COLETCHIE		1	46	
HEAV CLAY		46	78	
RED CLAY		78	102	
COLETCHIE		102	117	
RED CLAY		117	182	
SAND STONE		182	186	
RED CLAY		186	200	

RECEIVED
AUG 31 1978
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Aug 15, 1978
Date completed Aug 26, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 50 Draw down 8 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 200 feet
Casing record 8 ¼
Weight per foot 15 LBS Thickness 10 GAGE

Diameter	From	To
8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation TOUCH CUT
Size perforation ⅛
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 54-7 Feet below land surface 54-7
Flow G.P.M.
Water temperature NALD° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HOWARD T. EKENBERG
Address STAR ROUTE BOX 1050 JEAN NEV
Nevada contractor's license number 7484
Nevada driller's license number 679
Signed Howard T. Ekenberg
Date Aug 29, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471