

OFFICE USE ONLY
 Log No. 64018
 Permit No. 62581-T
 Basin 912

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15112

1. OWNER M. H., Inc. ADDRESS AT WELL LOCATION Shadow Creek Golf Course
 MAILING ADDRESS 3 Shadow Creek
No., Las Vegas, NV 89031

2. LOCATION NW 1/4 SW 1/4 Sec. 25 T 19 N/S R 61 E Clark County
 PERMIT NO. 62581-T APN 12425301001
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan Sandy Clay/ Boulders		0	32	32
Red Sandy Clay		32	175	143
Red Sandy Clay/ Gravels		175	265	90
Gravels/Red Clay		265	275	10
Red Clay		275	365	90
Red Clay/Gravels		365	380	15
Gravels/Red Sandy Clay		380	485	105
Green Clay/Sand Stringers		485	520	35
Green Blue Clay		520	540	20

8. WELL CONSTRUCTION
 Depth Drilled 540 Feet Depth Cased 520 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
Inches	Feet	Inches	Feet
<u>32</u>	<u>0</u>	<u>50</u>	<u>50</u>
<u>22</u>	<u>50</u>	<u>540</u>	<u>540</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>24</u>			<u>+1</u>	<u>50</u>
<u>16</u>			<u>+2</u>	<u>39</u>
<u>12</u>			<u>39</u>	<u>520</u>

Perforations:
 Type perforation Johnson Wire Screen
 Size perforation 060
 From 160 feet to 280 feet
 From 320 feet to 500 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 0 feet to 540 feet

9. WATER LEVEL
 Static water level 88 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

Date started 2/20, 19 97
 Date completed 3/20, 19 97

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>100</u>	<u>196</u>	<u>9</u>
Continuous			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co., Inc. Contractor
 Address 4185 W. Harmon Contractor
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 888 4285A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1851

Signed Richard K. Thompson
 By driller performing actual drilling on site or contractor
 Date 3/26/97