WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69023
Permit No.
Basin 162

NOTICE OF INTENT NO. 15847

1. OWNER Serenity Homes
MAILING ADDRESS 681 E. Harris Farm Rd.
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
681 E Harris Farm Rd. Pahrump, Nevada 89048

2. LOCATION SW 1/4 SE 1/4 Sec. 15 T 19S N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources
29-292-16 Parcel No.
Country Place II Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	14	14
Brown Grey Clay		14	26	12
Brown Calichia		26	49	23
Grey Calichia		49	68	19
Light Grey Calichia		68	84	16
Light Brown Clay		84	112	28
Brown Popcorn		112	134	22
Light Grey Calichia	x	134	148	14
Light Grey Clay	x	148	164	16
Brown Clay	x	164	178	14
Brown Clay and Gravel	x	178	200	22

Date started 3/8/97, 19__
Date completed 3/8/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	na	.50

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4	Inches	0 Feet	200 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	200

Perforations:
Type perforation TORCH
Size perforation .25 x 6
From 163 feet to 200 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025

Signed Larry Strickland
By driller performing actual drilling on-site or contractor

Date March 17 1997