

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 64028
 Permit No. 162
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15514

1. OWNER Bill Tuttle ADDRESS AT WELL LOCATION 3510 South Soplo Ave., Pahrump, Nevada 89048
 MAILING ADDRESS P. O. Box 82249
Las Vegas, NV 89180-2249

2. LOCATION NW 1/4 SE 1/4 Sec. 32 T 20S N/S R 53E E Nye County
 PERMIT NO. 40-581-11 Calvada Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light Grey Calichia		0	8	8
Light Brown Clay		8	22	14
Light Grey Popcorn		22	43	21
Brown Clay	x	43	60	17
Brown Popcorn	x	60	78	18
Light Brown Calichia	x	78	95	17
Light Brown Clay	x	95	119	24
Light Brown Calichia	x	119	131	12
Brown Clay	x	131	140	9

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 3/4 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17</u>	<u>188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation TORCH
 Size perforation .25 x 6
 From 100 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025

Signed Larry Strickland
 By driller performing actual drilling on-site or contractor

Date March 17, 1997

Date started 3/10/97, 19____
 Date completed 3/10/97, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>na</u>	<u>.50</u>

