WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64064
Permit No.
Basin 101

NOTICE OF INTENT NO. 261

1. OWNER Bill Corkill
MAILING ADDRESS 425 E Corkill Ln
Fallon, Nv 89406

ADDRESS AT WELL LOCATION 425 E Corkill Ln.
Fallon, Nv 89406

2. LOCATION NW ¼ NW ¼ Sec. 19 T. 18 N/S R. 29 E. Churchill County
PERMIT NO. Issued by Water Resources | 6-831-09 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Brown Sand		5	15	10
Brown Clay		15	18	3
Brown Sand		18	30	12
Brown Clay		30	40	10
Green Sand		40	45	5
Black Clay		45	65	20
Gray Sand		65	95	30
Green Clay		95	110	15
Brown Clay		110	115	5
Brown Sand	X	115	130	15

Date started May 30, 19 96
Date completed May 31, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	130 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	130

Perforations:
Type perforation Well Screen
Size perforation .030
From 125 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 120
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 120 feet to 130 feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nv 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (by driller performing actual drilling on site or contractor)

Date 7-1-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627