

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 64087  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29034

1. OWNER Gail Bailey ADDRESS AT WELL LOCATION 2420 Grisley, Reno, NV 89511  
 MAILING ADDRESS 1440 Hot Springs Rd  
Reno, NV 89511

2. LOCATION SW 1/4 NW 1/4 Sec. 32 T 18N N/S R 21E E Storey County \_\_\_\_\_  
 PERMIT NO. 03-022-69 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	8	8
Black stained granite		8	12	4
Brown clay w/black granite		12	48	36
See next line		48	60	12
Greenish clay & brown/red stain				
Grey clay		60	150	90
Grey pourous rock		150	205	55
Soft black pourous rock	xx	205	235	30
Hard black rock		235	245	10
Soft black rock		245	275	30
Green clay and rock		275	280	5
See next line		280	350	70
Green clay/rock w/ black pourous rock				

8. WELL CONSTRUCTION  
 Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 350 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	350

Perforations:  
 Type perforation Factory  
 Size perforation .060 x 3"

From <u>235</u>	feet to	<u>230</u>	feet
From <u>280</u>	feet to	<u>275</u>	feet
From <u>325</u>	feet to	<u>320</u>	feet
From <u>350</u>	feet to	<u>345</u>	feet
From _____	feet to	_____	feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 350 feet

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor  
 Date 6-24-96

Date started 6/14/96, 19\_\_\_\_  
 Date completed 6/18/96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>	<u>1 hr.</u>	