

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 64090
Permit No. _____
Cash 083

NOTICE OF INTENT NO 28296
2210 Musket Drive

1. OWNER **Todd Fargason**
MAILING ADDRESS **2210 Musket Drive**
Virginia City, NV

ADDRESS AT WELL LOCATION

2. Location **NE 1/4 SW 1/4 Sec 29 T 18N R 21E**
PERMIT NO. _____ PARCEL NO. **003-33-121**

Storey County
SUBDIVISION NAME **Highlands**

3. WORK PERFORMED	4. PROPOSED USE	5. WELL TYPE
<input checked="" type="checkbox"/> New Well <input type="checkbox"/> Deepen	<input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Municipal/Industrial	<input type="checkbox"/> Cable <input checked="" type="checkbox"/> Air
<input type="checkbox"/> Replace <input type="checkbox"/> Abandon	<input type="checkbox"/> Irrigation <input type="checkbox"/> Monitor	<input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Other
<input type="checkbox"/> Recondition <input type="checkbox"/> Other	<input type="checkbox"/> Test <input type="checkbox"/> Stock	<input type="checkbox"/> RVC <input type="checkbox"/> Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Red clay with red volcanic rock		0	7	7
Blue gray volcanic rock.		7	24	17
Red volcanic rock with red clay.		24	73	49
Red volcanic rock.		73	108	35
Purple & green volcanic rock fractured with traces of purple clay.		108	274	166

8. WELL CONSTRUCTION				
Depth Drilled	274 feet		Depth Cased	274 feet
HOLE DIAMETER (BIT SIZE)				
	From	To		
10 5/8 inches	0	feet	50	feet
8 1/2 inches	50	feet	274	feet
		feet		feet
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+1.5	274
Perforations::				
Type Perforation	factory			
Size perforation	1/8 x 3"			
From	260	feet to	220	feet
From		feet to		feet
From		feet to		feet
From		feet to		feet
From		feet to		feet
From		feet to		feet
Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:	
Depth of Seal	65	feet	Neat Cement	
		Pumped	Cement Grout	
		<input checked="" type="checkbox"/> Poured	<input checked="" type="checkbox"/> Concrete Grout	
Gravel Packed:	<input checked="" type="checkbox"/> Yes	No		
From	274	feet to	65	feet

9. WATER LEVEL
Static water level **104** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cool** Degrees F Quality

Date started **8-8 -96**
Date completed **8-10 -96**


7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
20+	96		2 1/2

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. **14170**
NV Driller's Lic (on site) **1511**

Signed 
By driller performing actual drilling on site or contractor
Date **8-14-96**