PPW-85

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64208
Permit No.
Basin 061

NOTICE OF INTENT NO. 33405

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ NE ¼ Sec. 30 T 36 (N) S R 50 E EUREKA County
PERMIT NO. 55150 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal (Mining) Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WASTE DUMP, FILL MATERIAL		0	103	103
WEATHERED GRANITE		103	114	11
FRESH GRAY-GREEN		114	1200	1086
DIORITE, SOME				
FRACTURES WITH				
CLAYS & PYRITE				

Date started JULY 25, 1996
Date completed AUGUST 8, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIRLIFT 10-60 GPM	TOTAL OF 58	HOURS	

8. WELL CONSTRUCTION
Depth Drilled 1200 Feet Depth Cased 1193.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
20-1/2 Inches	0 Feet	115 Feet	
15 Inches	115 Feet	625 Feet	
14-3/4 Inches	625 Feet	1260 Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42	.250	0	115
8	22.36	.250	0 (+1)	50.35

Perforations:
Type perforation LOUVERED SLOT
Size perforation .125 INCH
From 50.35 feet to 1193 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 FEET
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 53 feet to 1200 feet

9. WATER LEVEL
Static water level 637 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 68 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773

Signed MARK WAITE *Mark Waite*
By driller performing actual drilling on site or contractor

Date 8-8-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627