

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 321608

1. OWNER Sky West Development ADDRESS AT WELL LOCATION 3535 E. 5th St Silver Springs Nevada  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION SW 1/4 NW 1/4 Sec 116 T 17 N/S R 25 E County Stockton  
PERMIT NO. 17-361-09 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	16	16
Sand gravel		16	36	20
Sand Clay		36	59	23
Clay		59	78	19
Clay gravel	135	78	135	57
Sand gravel	146	135	146	11

8. WELL CONSTRUCTION  
Depth Drilled 146 Feet Depth Cased 147 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
10 5/8 Inches 1 Feet 146 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>1.88</u>	<u>13</u>	<u>71</u>	<u>146</u>

Perforations:  
Type perforation Tool joint  
Size perforation 3/16 x 1/4 x 1/8  
From 140 feet to 145 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 146 feet

9. WATER LEVEL  
Static water level 47 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature C °F Quality Good

Date started 2/22/96, 19\_\_\_\_  
Date completed 2/26/96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60-65</u>	<u>5 mo</u>	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Green Drilling Inc Contractor  
Address PO 559 Contractor  
S.S. NV 89429  
Nevada contractor's license number issued by the State Contractor's Board 0031841  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 3/1/96