

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29389

1. OWNER Larry Lapkin ADDRESS AT WELL LOCATION 3255 E. 3rd St. Silver Springs NV
 MAILING ADDRESS Po Box 1044 Cameliano Bay, Ca
 2. LOCATION NW 1/4 NW 1/4 Sec 9 T 17 N/S R 25 E LYON County
 PERMIT NO. 17-173-04 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand Gravel		0	25	25
Sand Gravel Boulders		25	50	25
Clay with Sand streaks		50	75	25
Fine Sand coarse Gravel		75	100	25
Clay with streaks of sand and gravel		100	125	25
Sand Big Gravel Cobbles		125	150	25
Sand washed Gravel		150	160	10

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased +1 to 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 160 Feet
 From 0 Feet To 160 Feet
 From 0 Feet To 160 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>188</u>	<u>+1</u>	<u>160</u>

Perforations:
 Type perforation factory milled
 Size perforation 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0 to 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 160 feet to 50 feet

9. WATER LEVEL
 Static water level N/A 37 feet below land surface
 Artesian flow N/A G.P.M. 10+ P.S.I.
 Water temperature Cold °F Quality Clear

Date started 3/29/96, 19____
 Date completed 3/29/96, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10+</u>		<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Enloe Drilling Contractor
 Address Po Box 1345 Contractor
Dayton NV 89403
 Nevada contractor's license number 4739 A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1757
 Division of Water Resources, the on-site driller
 Signed Troy Enloe
 By driller performing actual drilling on site or contractor
 Date 3/29/96