

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 319/15

1. OWNER Ron Norton ADDRESS AT WELL LOCATION 3095 Badger St. Silver Springs, NV
MAILING ADDRESS P.O. Box 892 Silver Springs, NV 89429
2. LOCATION NW 1/4 SW 1/4 Sec. 21 T. 17 N S R 25 E Lyon County Stockton #3
PERMIT NO. 17-484-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sandy Brown Soil</u>		<u>0</u>	<u>2</u>	<u>2'</u>
<u>Sandy brown clay</u>		<u>2</u>	<u>34</u>	<u>32'</u>
<u>Coarse Sand Brown</u>		<u>34</u>	<u>38</u>	<u>4'</u>
<u>Brown Clay</u>		<u>38</u>	<u>78</u>	<u>40'</u>
<u>Sandy Brown Clay</u>		<u>78</u>	<u>90</u>	<u>12'</u>
<u>Sand w/ gravel brown</u>	<u>-</u>	<u>90</u>	<u>100</u>	<u>10'</u>

8. WELL CONSTRUCTION
Depth Drilled 100' Feet Depth Cased 100' Feet

HOLE DIAMETER (BIT SIZE)
From To
10' Inches 0 Feet 50 Feet
6' Inches 0 Feet 100' Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>19</u>	<u>1/4"</u>	<u>0</u>	<u>100</u>

Perforations:
Type perforation Machined
Size perforation 18 x 2
From 91 feet to 98 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 feet con w/ Driller Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level: 37' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

Date started 9 May 1996
Date completed 13 May 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>12'</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon Cannon Contractor
Address 4555 Hwy 50 W Silver Springs, NV 89429 Contractor
Nevada contractor's license number 23317 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1190
Signed Tom Cannon
By driller performing actual drilling on site or contractor
Date 30 May 96