WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 64323
Permit No.
Basin 214

ERI. Quadra mining in Book

1. OWNER Bill Lules / Bob Smith ADDRESS Sarch Lite NV.

2. LOCATION SW ¼ NE ¼ Sec. 33 T. 28 N/S R. 64 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Mine Tailings		0	300	300
Frist Water	200'			
Main Water -				
Strata Thru -				
Fracture of Cold	280'			
Mine Shaft				
Develope with AIR				

RECEIVED
AUG 30 1984
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 8-2, 1984
Date completed 8-4, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	33	235	24
3450	44	260	4

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 300 feet
Casing record 6 5/8
Weight per foot Thickness 156

Diameter	From	To
6 5/8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation 1/8 x 5"
From 300 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 142 Feet below land surface 142
Flow G.P.M. 33
Water temperature 57 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vegas Drilling Co
Address 5956 Calvert
Nevada contractor's license number 015972
Nevada driller's license number 944
Signed Bruce Rahman
Date 8-28-84

USE ADDITIONAL SHEETS IF NECESSARY

O-627