WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 64328
Permit No.
Basin 214

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER GEORGE Campbell
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SE ¼ Sec. 32 T. 31 N/S R. 64 E Clark County
PERMIT NO. Issu
Parcel No.
Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Corse Sand & Gravel		0	68	68
Hard Cmt Gravel w/ Streak				
of Clay & Sand		68	625	547

Date started 7-30- 1986
Date completed 8-6- 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 625 feet
Casing record 0-625
Weight per foot 14 Thickness .156
Diameter 8⅝ inches From 0 feet To 625 feet
Surface seal: Yes ☑ No ☐ Type Cmt
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet
Perforations:
Type perforation Factory
Size perforation
From 500 feet to 520 feet
From 540 feet to 560 feet
From 580 feet to 600 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 415 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lee R Thomas (Contractor)
Address 5965 N. Maverick (Contractor)
Nevada contractor's license number 10831
Nevada contractor's drillers number 623
Nevada driller's license number 623 (Actual Driller)
Signed L R Thomas (Contractor)
Date 8-6-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) 0-427 CR434