

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **1183**

1. OWNER **O.M. GUILLARD** ADDRESS AT WELL LOCATION **3560 W. KEE ST (Lot 3) PANRUMPAN NV 89041**
 MAILING ADDRESS **6022 S. EUCLID LAS VEGAS, NV 89120-2403**

2. LOCATION **E 1/2 x SW 1/4 Sec 13 T 20 N/S R 52 E NYE** County _____
 PERMIT NO. **27-621-18** Issued by Water Resources Parcel No. _____ Subdivision Name **CHAS. PK RANCHOS**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	39	
SOFT BR CLAY	x	39	41	2
BROWN CLAY		41	78	37
SANDY BR. CLAY	x	78	92	14
HARD BR CLAY		92	94	2
BROWN CLAY		94	140	50
SOFT BR. CLAY	x	140	145	5
HARD BR CLAY		145	148	3
BROWN CLAY		148	160	12
HARD LIGHT BR CLAY		160	200	40

8. WELL CONSTRUCTION
 Depth Drilled **200** Feet Depth Cased **202** Feet

HOLE DIAMETER (BIT SIZE)
 From **12** Inches To **0** Feet **200** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	18	188	0	200

Perforations:
 Type perforation **Factory Cut**
 Size perforation **8 x 3**
 From **150** feet to **170** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **58'** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **58** feet to **200** feet

9. WATER LEVEL
 Static water level **38** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **Cold** °F Quality **Good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **O.M. GUILLARD DRILLING** Contractor
 Address **6022 S. EUCLID LAS VEGAS, NV 89120**
 Nevada contractor's license number issued by the State Contractor's Board **4796**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **115**
 Signed **O.M. Guillard** By driller performing actual drilling on site or contractor
 Date **4-7-97**

Date started **3-5** 1997
 Date completed **3-19** 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	15	20	45 Min

