



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15821

1. OWNER EDWIN & SHARON COOLEY ADDRESS AT WELL LOCATION 1801 WEST LABRADOR STREET  
 MAILING ADDRESS.....  
 2. LOCATION SE 1/4 NW 1/4 Sec. 32 T. 20-S N/S R. 53 E NYE County  
 PERMIT NO. 40-562-07 CALVADA VALLEY UNIT 5 BLOCK 13  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay		4	8	4
Brown clay & caliche		8	17	9
Gray clay		17	42	25
Gray clay & caliche	X	42	65	23
Brown clay		65	107	42
Brown clay & caliche		107	119	12
Brown clay	X	119	140	21

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:  
 Type perforation Torch cut  
 Size perforation 1/4" width 8" long  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 64 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started MARCH 26 19 97  
 Date completed MARCH 26 19 97

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
20	4	1/4	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name JIM PIKE WELL DRILLING, LLC Contractor  
 Address P.O. BOX 56 Contractor  
PAHRUMP, NV 89041  
 Nevada contractor's license number 17563A  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1812  
 Division of Water Resources, the on-site driller.  
 Signed Jim A. Pike  
 By driller performing actual drilling on site or contractor  
 Date MARCH 31, 1997