

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 64387  
 Permit No. 1102  
 Basin 1102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15770

1. OWNER **MEEKER, RONALD** ADDRESS AT WELL LOCATION 3891 RODEO AVE  
 MAILING ADDRESS 3891 RODEO AVE  
PAHRUMP, NV 89048

2. LOCATION SE 1/4 SW 1/4 Sec. 34 T 20S N/S R 53E E NYE County  
 PERMIT NO. 40-702-36 CALVADA VALLEY  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHIE		0	68	68
CALICHIE	WB	68	79	11
CLAY		79	92	13
CALICHIE	WB	92	103	11
CLAY		103	115	12
CALICHIE	WB	115	123	8
CLAY		123	132	9
CALICHIE	WB	132	140	8

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 140  
12.25 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:  
 Type perforation **FACTORY SAW CUT**  
 Size perforation 1/8 X 3  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 52 feet below land surfac  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 3/17/97, 19\_\_\_\_  
 Date completed 3/24/97, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Co. Contractor  
 Address PO BOX 4220 Contractor  
PAHRUMP, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dan  
 By driller performing actual drilling on-site or contractor  
 Date 3/31/97

