


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 64390
 Permit No. _____
 Basin 16a



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15759

1. OWNER **DICKMAN** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **4201 W RETREAD** **4201 W RETREAD**
PAHRUMP, NV 89048

2. LOCATION NE 1/4 SE 1/4 Sec. 14 T 20S N/S R 52E E NYE County _____
 PERMIT NO. 28-732-28 **CHARLESTON PARK RANCHOS**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHIE		0	61	61
CALICHIE	WB	61	73	12
CLAY		73	84	11
CALICHIE	WB	84	93	9
CLAY		93	108	15
CALICHIE	WB	108	117	9
CLAY		117	129	12
CALICHIE	WB	129	136	7
CLAY		136	140	4

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12.25 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:
 Type perforation **FACTORY SAW CUT**
 Size perforation 1/8 X 3

From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 46 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 3/10/97, 19____
 Date completed 3/14/97, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Great Basin Drilling Co.** Contractor
 Address **PO BOX 4220** Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board **30880**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed Thomas Dam
 By driller performing actual drilling on-site or contractor
 Date 3/24/97

