WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64393
Permit No.
Basin 162

NOTICE OF INTENT NO. 15757

1. OWNER CASWELL, NORMAN
MAILING ADDRESS 1731 W DUCK STREET
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION
1731 W DUCK STREET

2. LOCATION NE 1/4 NW 1/4 Sec. 8 T 19S N/S R 53E E NYE County
PERMIT NO. Issued by Water Resources | 27-251-17 Parcel No. | Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY & GRAVEL | | 0 | 108 | 108 |
| GRAVEL | WB | 108 | 119 | 11 |
| CLAY | | 119 | 135 | 16 |
| GRAVEL | WB | 135 | 148 | 13 |
| CLAY | | 148 | 170 | 22 |

Date started 3/17/97, 19__
Date completed 3/21/97, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

**8. WELL CONSTRUCTION**
Depth Drilled 170 Feet Depth Cased 170 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | To |
|---|---|---|---|
| 10.25 | Inches | 0 Feet | 170 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6.625 | 5.5 | .345 | 0 | 170 |
| | | | | |

**Perforations:**
Type perforation SAW CUT
Size perforation 1/8 X 4
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 170 feet

**9. WATER LEVEL**
Static water level 108 feet below land surfac
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Co. (Contractor)
Address PO BOX 4220 (Contractor)
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dem
By driller performing actual drilling on-site or contractor

Date 3/24/97

DCNR/DWR Received APR 10 1997