

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35362

1. OWNER Mike Horey ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 9403 Via Catalina Silver Springs NV 9403 Via Catalina
 2. LOCATION SE 1/4 NE 1/4 Sec. 25 T. 17 N/S R. 24 E. Lyon County
 PERMIT NO. 17-53501 17-535-07 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand</u>		<u>0</u>	<u>108</u>	<u>108</u>
<u>Sand Gravel</u>	<input checked="" type="checkbox"/>	<u>108</u>	<u>120</u>	<u>12</u>

RECEIVED
 27 FEB 13 PM 2:49
 WATER RESOURCES DIV

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
105/16 Inches From 0 Feet To 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>658</u>	<u>13.00</u>	<u>3/16</u>	<u>±1</u>	<u>120</u>

Perforations:
 Type perforation Touch cut
 Size perforation 11 1/2 Long 5 Rows
 From 110 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 0-50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 120 feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 1-15, 1997
 Date completed 1-17, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Produced about 30 GPM</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leadwell Drilling Contractor
 Address P.O. Box 899 Silver Springs NV 89489 Contractor
 Nevada contractor's license number 0031841 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 4877
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date _____