

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 533.170 and NAC 536.340

NOTICE OF INTENT NO. 33244
 ADDRESS AT WELL LOCATION 1275 e. 5th St.
Silver Springs, NV 89429

1. OWNER Rich Gwin ADDRESS AT WELL LOCATION 1275 e. 5th St.
 MAILING ADDRESS 1275 E. 5th St.
Silver Springs, NV 89429
 2. LOCATION NW 1/4 NE of NW 4 Sec. 18 T. 17 S. R. 25 East Lyon County
 PERMIT NO. 17-272-01 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand fine		0	20	20
Brown clay soft		20	75	55
Gray clay		75	95	20
Multi colored course sand		95	120	25
Multi colored Gravel	X	120	140	20
T.D. 140'				

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1 1/2	140

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 X 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800 1/2 Frazer Ave. Contractor
Sparks, NV 89431
 Nevada contractor's license number 35387-A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1509T-1
 Division of Water Resources, the on-site driller
 Signed Larry Welch
 By driller performing actual drilling on site or contractor
 Date February 17, 1997

Date started February 12, 1997
 Date completed February 13, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 Hours</u>