

Log No. 64468
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35360

1. OWNER Louis Karchen ADDRESS AT WELL LOCATION 9870 Via Catalina
 MAILING ADDRESS _____ Silver Springs, Nev. 89429
 2. LOCATION SW 1/4 SW 1/4 Sec. 30 T. 17 N. 25 E. County Nyon
 PERMIT NO. 15-581-08 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mad

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>92</u>	<u>92</u>
<u>Clay</u>		<u>92</u>	<u>112</u>	<u>20</u>
<u>Sand some gravel</u>		<u>112</u>	<u>142</u>	<u>30</u>
<u>Gravel</u>		<u>142</u>	<u>160</u>	<u>18</u>

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 160 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>+1</u>	<u>160</u>

Perforations:
 Type perforation Touch Cut
 Size perforation 1 1/4 x 60 rows
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 44 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 1-22 1997
 Date completed 1-29 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>Produced about 50 GPM</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Joseph Dillier Inc Contractor
 Address 10500 N 599 Contractor
Silver Springs NV 89429
 Nevada contractor's license number 0031891
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1877
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date _____