WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64470
Permit No.
Basin 083

NOTICE OF INTENT NO. 30653

1. OWNER RUSSELL HENRY JR.
MAILING ADDRESS 1100 Marietta Way
Sparks, Nevada 89431

ADDRESS AT WELL LOCATION 870 Buckeye
Virginia City, Nevada 89440

2. LOCATION SE ¼ SE ¼ Sec. 30 T 18N N/S R 21 E Storey County
PERMIT NO. (Issued by Water Resources) 003-541-25 (Parcel No.) Virginia City Highlands (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TEST HOLE ABANDONMENT				
December 3, 1996				
Attempt to measure static water level				
with sounding line. Obstruction in				
hole at 370 feet.				
Drilling equipment was set up over test hole.				
The drill bit was lowered to 664 feet.				
At this point hole was caving in.				
An attempt to clean caving material was				
terminated at 695 feet.				
Test hole was not yielding water.				
December 4, 1996				
Test hole was abandoned by back filling				
bore hole with 10 yards of clean sand and				
cement plugging from 0 to 51 feet with neat				
cement. (25 sacks of Type II Cement)				
Equipment used:				
Ingersoll-Rand T4W Drill				
Ford LT 9000 Support Truck				
Location:				
Apprx. 15 feet of West boundry				
150 feet North of Buckeye				

Date started 12-3-96, 19
Date completed 12-4-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date December 5, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627