

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35373

1. OWNER Steve Henry ADDRESS AT WELL LOCATION 5905 Dayton Ave  
 MAILING ADDRESS Silver Springs NV 89429  
 2. LOCATION NW 1/4 SW 1/4 Sec 32 T 18 N/S R 24 E LYON County  
 PERMIT NO. 18-45305 Parcel No. Holly wood Hills Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Dirt &amp; silt</u>				
<u>Some gravel</u>		<u>0</u>	<u>43</u>	<u>43'</u>
<u>Clay &amp; gravel</u>		<u>43</u>	<u>58</u>	<u>15'</u>
<u>Cemented gravel</u>		<u>58</u>	<u>340</u>	<u>282'</u>
<u>Loose Gravel</u>	<u>✓</u>	<u>340</u>	<u>350</u>	<u>10'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 350' Feet Depth Cased 351' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 3/8 Inches 0 Feet 60' Feet  
8 3/4 Inches 60 Feet 350' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>1300</u>	<u>1 8/8</u>	<u>+1</u>	<u>350'</u>

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4 x 6" 5 Rows  
 From 330' feet to 350' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 60' feet to 350' feet

9. WATER LEVEL  
 Static water level 320' feet below land surface  
 Artesian flow NA G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Clear

Date started 3-4 1997  
 Date completed 3-6 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>10 GPM</u>	<u>FEEM</u>	<u>350' ft -</u>	
<u>FOR</u>	<u>TWO HOURS</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leach Drilling Inc. Contractor  
 Address PO Box 599 Contractor  
Silver Springs NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3/10/97