WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64477
Permit No.
Basin 087

NOTICE OF INTENT NO. 32020B

1. OWNER Pureline, Inc. dba Crystal Springs Water Co.
MAILING ADDRESS 901 S. Center St.
Reno, NV 89501

ADDRESS AT WELL LOCATION 901 S. Center St.

2. LOCATION SW 1/4 NW 1/4 Sec. 13 T 19N N/S R 19E E Washoe County
PERMIT NO. 04573 (VESTED CLAIM) Issued by Water Resources | 011-334-13 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other _____

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We abandoned this well by				
perforating from total depth of				
212' up to 152'. Then we				
perforated again at 48'-65' with				
very heavy perforations. We then				
perforated between 13' and 28' with				
heavy perforations. We then pumped				
2.5 yards of neat cement and filled				
from the bottom up to surface using				
tremie pipe and pressure grout				
pump.				
OLD WELL				

Date started 2/5/97, 19__
Date completed 2/7/97, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	260 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	19.0	.250	+1	250

Perforations:
Type perforation Torch cut
Size perforation 1/4" X 8"
From 240 feet to 250 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal _____
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 2-7-97