WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64489
Permit No.
Basin 101

NOTICE OF INTENT NO. 30921

1. OWNER RENNER FARM EQUIPMENT
MAILING ADDRESS 1510 W. WILLIAMS ST. FALLON, NV.
ADDRESS AT WELL LOCATION SAME

2. LOCATION C ¼ D ¼ Sec. 25 T. 19 ~~28~~ N/S R. 28 E. CHURCHILL County
PERMIT NO. OLD m/o 1063 (Issued by Water Resources) 01-231-40 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other AUGER

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
ON 11/27/96, I	7'			
FOUND THE WELL				
TO BE IN GOOD				
CONDITION. AFTER				
REMOVING THE				
COVER, I THEN				
DRILLED THE 2"				
CASING OUT				
TO 20'. I				
THEN PRESSURE				
GROUTED THE				
HOLE WITH				
NEAT CEMENT				
FROM 20' TO				
THE SURFACE				

Date started 11/27, 1996
Date completed 11/27, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 20' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
6"	0'	20'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	SCH.40	PVC	0'	20'

Perforations:
Type perforation FACTORY
Size perforation .020
From 5' feet to 20' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 20'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 7' feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1655 BELFORD RD. (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12/10/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627