WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64502
Permit No.
Basin 092B

NOTICE OF INTENT NO. 35486

1. OWNER STEVE & JENNY MENDIETA
MAILING ADDRESS 110 Heindel Road
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
Heindel Road
Reno, Nevada 89506

2. LOCATION NW ¼ NE ¼ Sec. 16 T. 20N N/S R. 19E E. Washoe County
PERMIT NO. (Issued by Water Resources) 082-660-20 (Parcel No.) Black Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil & Small boulders		0	3	3
Brown clay with gravel		3	21	18
Softer brown clay with gravels		21	31	10
Brown sandy clays		31	69	38
Brown sandy clays with gravels		69	96	27
Brown clay with boulders, gravels		96	140	44
Soft zone (sands)		140	145	5
Brown sandy clay with gravels		145	211	66
Brown clay with gravels		211	285	74
Weathered volcanic rock		285	334	49
Gray volcanic rock		334	369	35
Fracture (app 12 GPM)	X	369	371	2
Gray volcanic rock		371	403	32
Fracture	X	403	417	14
Gray volcanic rock		417	425	8

Date started 1-20-97, 19
Date completed 1-27-97, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
37+		

8. WELL CONSTRUCTION
Depth Drilled 425 Feet Depth Cased 425 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	425	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"		.188	0	425

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 380 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 51 feet to 425 feet

9. WATER LEVEL
Static water level 175 feet below land surface
Artesian flow G.P.M. 37+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date January 28, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627