

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 34193
 KAISER M...MILL

1. Consultant: ERM-West, Inc. Client: _____
 1. OWNER: ERM-West, Inc. ADDRESS AT WELL LOCATION: _____
 MAILING ADDRESS: 455 Capitol Mall, Suite 800 Sparks, NV
 Sacramento, CA 95814
 2. LOCATION: N 1/4 SE 1/4 Sec. 32 T. 20N N/S R. 22 E Storey County
 PERMIT NO. M/O 1087 MW#-2 1-A 4-091-27 East of Sparks, NV
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, brown, coarse well graded, dry, loose		0	5	5
Gravelly sand, brown & grey, coarse, gravel dia. ≤ 1"		5	9	4
Sandy gravel, grey & brown, tightly compacted, coarse, gravel dia. ≤ 2"		9	15	6
Gravel & cobbles, grey coarse, varying dia. (some as large as approx. 20")		15	43	28
Gravel & cobbles with trace amounts of fine sand & silt, grey & brown, poorly graded, wet		43	52	9
Gravelly sand, brown & grey, gravel particles are smaller, sand is large-graded, coarse & poorly-graded, wet		52	64.5	12.5

8. WELL CONSTRUCTION
 Depth Drilled: 64.5 Feet Depth Cased: 42.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 64.5 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" ID		Sch 80 PVC	0	42.4

 Locking Cap / Steel Monument 8" x 5"
 SS Centralizers at 18', 38', 58' End Cap
 Perforations:
 Type perforation: factory sawed slot
 Size perforation: 0.020 inch
 From 42.5 feet to 62.5 feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal: 5' concrete / 5-36 ft. Cement Grout
 Placement Method: Pumped Concrete Grout
 Bentonite Seal: 36 - 38ft.
 Gravel Packed: Yes No
 From 38 feet to 64.5 feet

Date started: 10-30-96, 19____
 Date completed: 10-30-96, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No test			

9. WATER LEVEL
 Static water level: 43 feet below land surface
 Artesian flow: _____ G.P.M. N/A P.S.I.
 Water temperature: not known Quality: not known

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name: WAYNE DRILLING, INC. Contractor
 Address: P.O. BOX 12370 Contractor
 RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board: 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 908
 Signed: _____ By driller performing actual drilling on site or contractor
 Date: December 16, 1996