

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34/164
I-80 - Patrick exit

1. OWNER Kal KAW FOODS, INC ADDRESS AT WELL LOCATION Storey county, Nv
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SW 1/4 Sec. 32 T. 20 N. S. R. 22 E Storey County
 PERMIT NO. MO 1077 Issued by Water Resources 004 161 01 Parcel No. Storey Subdivision Name

M
W
#4

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>MW-4</u>				
<u>grey poorly graded sand - some gravel lenses</u>		<u>0'</u>	<u>29'</u>	
<u>grey gravelly sand with rounded gravel</u>		<u>29'</u>	<u>36'</u>	
<u>grey poorly graded sand</u>		<u>36'</u>	<u>44'</u>	
<u>Sandy gravel with cobbles</u>		<u>44'</u>	<u>47.5'</u>	
<u>Brown silty sand</u>		<u>47.5'</u>	<u>53'</u>	

8. WELL CONSTRUCTION
 Depth Drilled 53 Feet Depth Cased 46.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 53 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.37</u>		<u>sch 40</u>	<u>0</u>	<u>25.5</u>
<u>2.37</u>		<u>sch 40</u>	<u>41.5</u>	<u>46.5</u>

Perforations:
 Type perforation SLOT
 Size perforation 0.10
 From 26.5 feet to 41.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 24.5
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 24.5 feet to 53 feet

Date started 9-9, 1996
 Date completed 9-9, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 37.62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NeuMOA Drilling Inc Contractor
 Address 75 Lewers creek RD Contractor
Carson City NV. 89704
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1902
 Division of Water Resources, the on-site driller
 Signed John B. Peisak
 By driller performing actual drilling on site or contractor
 Date 2.22.97