

OFFICE USE ONLY
Log No. 4524
Permit No. _____
Basin. 092B
I
NOTICE OF INTENT NO. 30629

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SCOTT OSBORN ADDRESS AT WELL LOCATION Same
MAILING ADDRESS 11715 Juniper
Reno, Nevada 89506

2. LOCATION NW 1/4 NE 1/4 Sec 15 T 21N N/S R 19 E Washoe County
PERMIT NO. 080-41-408 Lemmon Valley
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Bottom of well @160 feet, Yield				GPM
Brown clay		160	162	2
Medium to fine brown sand	X	162	174	12
Weathered granite		174	188	14
Green to weathered granite, some small clay streaks		188	240	52
Fracture	X	240	241	1
Green to gray granite		241	266	25

39.69/181°N - GPS
119.834/116°W
plugged by well log #112622

8. WELL CONSTRUCTION
Depth Drilled 266 Feet Depth Cased 266 Feet

HOLE DIAMETER (BIT SIZE)
From 6 1/8 Inches To 160 Feet 266 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	266

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 160 feet to 180 feet
From 200 feet to 220 feet
From 240 feet to 260 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal deepening Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 160 feet to 266 feet

Date started 10-17-96, 19____
Date completed 10-18-96, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>		

9. WATER LEVEL
Static water level 152 feet below land surface
Artesian flow _____ G.P.M. 10 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. Contractor
Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
Signed [Signature] By driller performing actual drilling on site or contractor
Date October 21, 1996