WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64527
Permit No.
Basin 092B

1. OWNER Brady B. Jr
MAILING ADDRESS 3052 Lido Lane
Sparks 89431

NOTICE OF INTENT NO. 30185
ADDRESS AT WELL LOCATION 11735 Juniper Reno

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 21 N/S R. 19 E. W/S Washoe County
PERMIT NO. 5794 Issued by Water Resources
080-416-04 Parcel No.
Lemon Valley Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Dirt		0	21	21
Yellow Brown Clay		21	28	7
Brown Sandy Clay		28	92	64
Red Clay		92	99	7
Brown Sandy Clay		99	118	19
Course Sand		118	199	81
Brown D.G.		199	212	13
Hard Gray Granite		212	255	43
Broken Gray Granite	20	255	275	20

Date started 1-27, 19 97
Date completed 1-27, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	12	16	6

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	212 Feet
6¼ Inches	212 Feet	275 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝		.188	+1	212
5⅝		.188	208	275

Perforations:
Type perforation Factory Slot
Size perforation ⅞" x 3"
From 255 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 55 feet to 212 feet

9. WATER LEVEL
Static water level 151 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JM Drilling Contractor
Address 1859 Hymer Contractor
Sparks NV 89431
Nevada contractor's license number issued by the State Contractor's Board 41172
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1940
Signed [signature] By driller performing actual drilling on site or contractor
Date 1-27-97

(Rev. 3 91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627