WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK 26BCC

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64532
Permit No.
Basin 093

NOTICE OF INTENT NO. 30614

1. OWNER MARK & CYNTHIA LAUDENSLAGER
MAILING ADDRESS J/L Builders 10900 Red Rock Rd
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 9715 Matterhorn Blvd.
Reno, Nevada 89506

2. LOCATION SW ¼ NW ¼ Sec. 26 T 22N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 079-450-~~23~~ 85 (Parcel No.) Washoe Red Rock Est. #273 Part 1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soft brown sands		0	5	5
Brown sandy clay		5	19	14
Soft zone brown sand		19	21	2
Brown sandy clay		21	69	48
Soft zone, coarse decomposed granite		69	71	2
Brown sandy clay		71	118	47
Brown clay		118	125	7
Medium to coarse sand, granite sands	X	125	145	20

RECEIVED 96 OCT 21 PM 2:10 STATE ENGINEER'S OFFICE

Date started 10-10-96, 19
Date completed 10-11-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	145 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	145

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 145 feet

9. WATER LEVEL
Static water level 69 feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature]
By driller performing actual drilling on site or contractor
Date October 16, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627