

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33236

1. OWNER Adrian Beard ADDRESS AT WELL LOCATION 300 Chieftan
 MAILING ADDRESS 40 Riverson Ct. Sparks, NV 89436
 2. LOCATION NE 1/4 SE 1/4 Sec 2 T 22 OS R 21 East Washoe County
 PERMIT NO. 076-470-06 Monte Cristo Ranch Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	10	10
Multi colored volc rock		10	20	10
Green & purple volc rock		20	23	3
Purple clay sticky		23	26	3
Purple volc rock		26	35	9
Gray reddish clay		35	37	2
Gray reddish volc rock	X	37	120	83
Red & gray volc rock	soft	120	155	35
Green & gray volc rock	soft	155	165	5
Green & red volc rock	soft	165	170	5
Gray & red volc rock	soft	170	190	20
Blue & red volc rock	soft	190	205	15
Gray volc rock	soft	205	215	10
Green & gray volc		215	225	10
Multi colored volc rock	X	225	230	5
Dark gray volc rock		230	235	5
Multi colored volc rock	X	235	240	5
Greenish gray volc rock		240	245	5
Multi colored volc rock	hard	245	270	25
T.D.		270'		

8. WELL CONSTRUCTION
 Depth Drilled 270' Feet Depth Cased 270' Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 100' Feet
10 5/8 Inches
 From 100' Feet To 270' Feet
8 1/2 Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	188	+1 1/2	270'

Perforations:
 Type perforation Factory Sawed
 Size perforation 3/32 x 3
 From 250' feet to 230' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 90 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 270' feet to 90' feet

9. 20' WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started December 17, 1996
 Date completed December 20, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>2 Hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800 1/2 Frazer Ave. Contractor
Sparks, NV 89431
 Nevada contractor's license number 35387-A issued by the State Contractor's Board
 Nevada driller's license number issued by the 1509 Division of Water Resources, the on-site driller
 Signed Larry Welch By driller performing actual drilling on site or contractor
 Date Dec. 31, 1996